

## Circulating Fluid Temperature Controller Thermo-chiller Inverter Type

# HRSH090 Series


# Power consumption reduced by $53\%^{*1} \in E$





Intertek

RoHS)




### Inverter pump

Power reducing effect of the inverter pump Inverter pump Existing model HRSH090 55 L/min 35 L/min ower consumption Power consumption verte (Pump only) pump (Pump only) Tank Tank .6 kW kW 35 L/min 55 I /min 35 L/min 0.3 MPa 35 L/min 0.3 MPa User's equipment The pump is operated at The motor rotation User's equipment the rated output all the rate is controlled H time. With the excess Non-inverter pump to a suitable level, Inverter pump power consumption, the for the necessary 20 L/mir circuit needs to bypass 20 pressure, by the inverter pump L/min

### Circulating fluid pressure adjustable

Discharge pressure of the circulating fluid can be set with the operation panel. The inverter pump automatically controls the discharge pressure to the set pressure without adjusting the bypass piping under various piping conditions. Power consumption can be reduced by this control. (Operation to the set pump operating frequency is also possible.)




When the product is used with the flow path switched for maintenance, the pressure adjusting function controls the discharge pressure to be stable. (Secure the specified minimum flow for each branch circuit.)



#### Variations

<b>v</b> anationio						
Model	Cooling method	Cooling capacity	Power supply	Option Page 298	Optional accessories Pages 299 to 302	International standards
	Air-cooled refrigeration	9.5 kW	· 3-phase 200 VAC (50 Hz), 3-phase 200 to 230 VAC (60 Hz)	With earth leakage breaker (For 400 V type as standard) With automatic fluid fill function	n earth sage breaker 00 V type as standard) n automatic till function (4) Piping conversion fitting • Bypass piping set • Electric conductivity control set	<b>( € 분</b> (400 V as standard)
	Water-cooled refrigeration	11.0 kW	· 3-phase 380 to 415 VAC (50/60 Hz) 3-phase 460 to 480 VAC (60 Hz)	Applicable to deionized water piping     Compliant with CE/UKCA, UL standards     SI unit only	Filter for circulating     fluid fill port	(Only 200 V as an option)

#### Circuit diagram



- The DC inverter compressor compresses the refrigerant gas and discharges high-temperature, high-pressure refrigerant gas.
- In the case of air-cooled refrigeration, the high-temperature, high-pressure refrigerant gas is cooled down by DC inverter fan ventilation in the air-cooled condenser, where it is then liquefied. In the case of water-cooled refrigeration, the refrigerant gas is cooled by the facility water in the facility water circuit in the water-cooled condenser, where it is then liquefied.
- The liquefied high-pressure refrigerant gas expands and its temperature lowers when it passes through expansion valve A, where it vaporizes after receiving heat from the circulating fluid in the evaporator.
- The vaporized refrigerant gas is sucked into the DC inverter compressor and compressed again.
- When heating the circulating fluid, the high-pressure, high-temperature refrigerant gas is bypassed into the evaporator by expansion valve B to heat the circulating fluid.



The combination of inverter control of the compressor and fan (facility water flow control by a water-regulating valve is used in water-cooled refrigeration), and the precise control of expansion valves A and B realizes energy saving operation without waste and high temperature stability.


- After the circulating fluid discharged from the inverter pump is heated or cooled by the user's equipment, it returns to the tank.
- The circulating fluid is sent to the evaporator by the inverter pump, and is controlled to remain at a set temperature by the refrigeration circuit. It will then be discharged to the user's equipment side again by the thermo-chiller.



Adjusting the discharge pressure by pump inverter control eliminates wasteful discharge of the circulating fluid and realizes energy saving operation.




Since the refrigeration circuit is controlled by the signals from 2 temperature sensors (for return and discharge), precise temperature control of the circulating fluid can be achieved. Therefore, there is no need for a tank with a large capacity to absorb the circulating fluid temperature difference, as high temperature stability can be achieved even with a small-size tank. This also contributes to space saving.



**SMC** 

Circulating Fluid Temperature Controller
Thermo-chiller Inverter Type HRSH090 Series



#### **Circulating Fluid Temperature Controller** Thermo-chiller Inverter Type HRSH090 Series


#### Convenient functions (Refer to the Operation Manual for details.)


#### Timer operation function

Timer for ON and OFF can be set in units of 0.5 h up to 99.5 h.

Ex.) Can be set to stop on Saturday and Sunday and restart on Monday morning

#### Ex. SE.02 "ON timer"





Unit conversion function

Temperature and pressure units can

#### Power failure auto-restart function

Automatic restart after stoppage due to power failure, etc., is possible without pressing the key, and remote operation is also possible.

Anti-freezing operation function

If the circulating fluid approaches its freezing point, for example, on a cold winter night, the pump operates automatically, and the heat generated by the pump warms the circulating fluid, preventing freezing.

Key-lock function Can be set in advance to protect the set values from being changed by pressing keys by mistake.

Function to output a signal for completion of preparation Notifies by communication when the temperature reaches the pre-set temperature range

Independent operation of the pump The pump can be operated independently while the chiller is powered off. This allows you to check for leakages in piping and to remove the air.

#### Self-diagnosis function and check display


Display of individual alarm codes For details, refer to page 296. Operation is monitored at all times by the integrated sensor.

Should any error occur, the self-diagnosis result is displayed by the applicable alarm code.

This makes it easier to identify the cause of the alarm.

Can be used before requesting service


Changeable alarm set values				
Setting item	Set value			
Circulating fluid discharge temperature rise	5 to 55°C			
Circulating fluid discharge temperature drop	1 to 39°C			
Circulating fluid discharge pressure rise	0.05 to 0.6 MPa			
Circulating fluid discharge pressure drop	0.05 to 0.6 MPa			



#### Alarm codes can be used for the notification of upcoming recommended maintenance. The codes notify you when it's time to check the


.....


pump and fan motor. Helpful for facility maintenance A fan motor is not used in water-cooled refrigeration.



#### **Check display**

The internal temperature, pressure, and operating time of the product are displayed.






- Use it for reference.
- \*2 These are displayed only for air-cooled refrigeration.

#### **Communication function**

Serial communication (RS232C/RS485) and contact I/Os (2 inputs and 3 outputs) are equipped as standard. This allows for communication with the user's equipment and system construction, depending on the application. A 24 VDC output can be also provided and is available for use with flow switches (SMC's PF2W, etc.).


#### Remote signal I/O through Ex. 1) serial communication

Remote operation is enabled (to start and stop operation) through serial communication.



#### Ex. 2 Remote operation signal input


One of the contact inputs is used for remote operation and the other is used to monitor the flow of a flow switch. This is where their alarm outputs are taken in.



SMC

#### Ex. 3 Alarm and operation status (start, stop, etc.) signal output

The alarm and status generated in the product are assigned to 3 output signals based on their contents, which can then be output.



# CONTENTS HRSH090 Series Inverter Type



#### Thermo-chiller HRSH090 Series

#### How to Order/Specifications

Air-cooled 200 V/400 V	Page 291
Water-cooled 200 V/400 V	Page 292
Cooling Capacity	Page 293
Pump Capacity	Page 293
Dimensions	Page 294
Recommended External Piping Flow	Page 295
Cable Specifications	Page 295
Operation Display Panel	Page 296
List of Function	Page 296
Alarm	Page 296
Communication Functions	Page 297

#### Options

With Earth Leakage Breaker	Page 298
With Automatic Fluid Fill Function	Page 298
Applicable to Deionized Water Piping	Page 298
Compliant with CE/UKCA, UL Standards	Page 298
SI Unit Only	Page 298

#### Optional Accessories

① Piping Conversion Fitting ······	Page 299
② Bypass Piping Set	Page 299
③ Electric Conductivity Control Set	Page 300
④ Particle Filter Set ······	Page 300
5 Filter for Circulating Fluid Fill Port	Page 301
6 Drain Pan Set (With Water Leakage Sensor)	Page 301
⑦Wired Remote Controller	Page 302


#### Cooling Capacity Calculation

Required Cooling Capacity Calculation Page 303
Precautions on Cooling Capacity Calculation ··· Page 304
Circulating Fluid Typical Physical Property Values ··· Page 304

Specific Product Precautions	Page 305
------------------------------	----------

Maintenance Service p. 23





#### Specifications

Model			lodel		HRSH090-A□-20-□	HRSH090-A□-40-□	
Cooling method					Air-cooled refrigeration		
Refrigerant					R410A (HFC)		
Refrigerant charge kg				kg	1.32		
Co	ntrol metho	bd			PID c	ontrol	
Am			nidity/Altitude*1,9	°C/%	Temperature: 5 to 45°C, Humidity: 30 to 70%, Altitude: less than 3000 m		
	Circulatin	g fluid*2			Tap water, 15% Ethylene glycol aqueous solution, Deionized water		
	Set tempe			°C	5 tc	0 40	
	Cooling c	apacity*	3, 9	kW	9	.5	
stem	Heating c			kW	2	.5	
ste	Temperat	ure stabi	ility*5	°C	±C	).1	
sy	Pump	Rated f	low (Outlet)	L/min	45 (0.5	5 MPa)	
fluid	capacity		um flow rate	L/min	6		
			um pump head	m	5	0	
Circulating	Settable p	ressure	range*6	MPa	0.1 t	o 0.5	
ati	Minimum	operatin	g flow rate*7	L/min	20		
2	Tank capa			L	18		
Ë.	Circulating fluid outlet, circulating fluid return port			return port	Rc1 (Symbol F: G1, Symbol N: NPT1)		
Ŭ	Tank drain port				Rc1/4 (Symbol F: G1/	4, Symbol N: NPT1/4)	
	Fluid contact material				Stainless steel, Copper (Heat exchanger brazing), Brass, Bronze, Carbon, Ceramic, PE, PVC, POM, PTFE, NBR, EPDM, FKM, PP		
Power supply			3-phase 200 VAC (50 Hz), 3-phase 200 to 230 VAC (60 Hz) Allowable voltage range ±10% (No continuous voltage fluctuation)	3-phase 380 to 415 VAC (50/60 Hz) Allowable voltage range ±10% (No continuous voltage fluctuation) 3-phase 460 to 480 VAC (60 Hz) Allowable voltage range +4%, -10% (Max. voltage less than 500 V and no continuous voltage fluctuation)			
ž	Applicable	earth*8	Rated current	Α	30	20	
Electrical	leakage bro		Sensitivity of leak cur	rent mA	3	0	
ш	Rated ope	erating c		Α	15	8	
	Rated power consumption*5 kW		kW (kVA)	4.6 (5.2)	5.0 (5.6)		
Noise level (Front 1 m/Height 1 m)*5 dB (A)			Height 1 m)*5	dB (A)	66		
Accessories					Alarm code list stickers 2 pcs. (English 1 pc./Japanese 1 pc.), Operation Manual (for installation/operation) 2 pcs. (English 1 pc./Japanese 1 pc.), Y-strainer (40 meshes) 25A, Barrel nipple 25A, Anchor bolt fixing brackets 2 pcs. (including 4 M10 bolts)* <sup>10</sup>		
Weight (dry state) kg				kq	Approx. 130		
				v	ing in a place where the ambient temperature and/or circulatir		

Use fluid in condition below as the circulating fluid. \*2

Tap water: Standard of The Japan Refrigeration And Air Conditioning Industry Association (JRA GL-02-1994) 15% ethylene glycol aqueous solution: diluted by tap water in condition above without any additives such as antiseptics. Deionized water: Electric conductivity 1  $\mu$ S/cm or higher (Electric resistivity 1 M $\Omega$ ·cm or lower)


\*3 ① Ambient temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid temperature: 20°C, ④ Circulating fluid flow rate: Rated flow, ⑤ Power supply: 200/400 VAC
 \*4 ① Ambient temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid flow rate: Rated flow, ④ Power supply: 200/400 VAC
 \*5 ① Ambient temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid temperature: 20°C, ④ Load: Same as the cooling capacity,

© Circulating fluid flow rate: Rated flow, © Power supply: 200/400 VAC, © Piping length: Shortest
 \*6 With the pressure control mode by inverter. When the pressure control mode is not used, the pump power frequency set mode can be used.

Fluid flow rate to maintain the cooling capacity. If the actual flow rate is lower than this, install a bypass piping.

\*8 To be prepared by the user. A specified earth leakage breaker is installed for option B [With earth leakage breaker], option S [Compliant with CE/UKCA, UL Standards] and 400 V type.
\*9 If the product is used at an altitude of 1000 m or higher, refer to "Operating Environment/Storage Environment" (page 305) Item 14 "For altitudes of 1000 m or higher."
\*10 The anchor bolt fixing brackets (including 4 M10 bolts) are used for fixing to wooden skids when packaging the thermo-chiller. No anchor bolt is included.





#### Specifications

Model			lodel		HRSH090-W□-20-□	HRSH090-W□-40-□	
Cooling method					Water-cooled refrigeration		
Refrigerant					R410A (HFČ)		
				kg	1.4		
Co	ntrol metho	d			PID control		
Am	pient tempera	ature/Hum	idity/Altitude*1	°C/%	Temperature: 5 to 45°C, Humidity: 30 to 70%, Altitude: less than 3000 m		
	Circulatin	g fluid*2	-		Tap water, 15% Ethylene glycol aqueous solution, Deionized water		
	Set tempe	rature ra	ange*1	°C	5 to 40		
	Cooling capacity*3 kW			kW	11.0		
E	Heating ca	apacity*4	4	kW	2.5		
system	Temperature stability <sup>*5</sup> °C			°C	±0.1		
	Pump	Rated f	low (Outlet)	L/min	45 (0.5	5 MPa)	
pir		Maximu	Im flow rate	L/min	6	0	
Ę	capacity		Im pump head	m	5	0	
ng	Settable p	ressure	range*6	MPa	0.1 to	o 0.5	
Circulating fluid	Minimum	operating	g flow rate*7	L/min	2	0	
C.	Tank capa	city		L	1	8	
5	Circulating	fluid outle	et, circulating fluid	return port	Rc1 (Symbol F: G1	, Symbol N: NPT1)	
Ŭ	Tank drain	n port			Rc1/4 (Symbol F: G1/4	4, Symbol N: NPT1/4)	
	Fluid cont	act mate	erial		Stainless steel, Copper (Heat exchanger brazing), Brass, Bronze, Carbon, Ceramic, PE, PVC, POM, PTFE, NBR, EPDM, FKM, PP		
F	Temperature range °C		°C	5 to 40			
system	Pressure range MPa			0.3 to			
ŝ				L/min	2		
ater				MPa	0.3 or	-	
Ň	Facility water inlet/outlet			ini u	Bc		
l≣.					Stainless steel, Copper (Heat exchanger brazing), Bronze, Brass,		
Facility water	Fluid cont	act mate	erial		PTFE, NBR, EPDM		
Electrical system	Power sup	oply			3-phase 200 VAC (50 Hz), 3-phase 200 to 230 VAC (60 Hz) Allowable voltage range ±10% (No continuous voltage fluctuation)	3-phase 380 to 415 VAC (50/60 Hz) Allowable voltage range ±10% (No continuous voltage fluctuation) 3-phase 460 to 480 VAC (60 Hz) Allowable voltage range +4%, -10% (Max. voltage less than 500 V and no continuous voltage fluctuation)	
Ţ.	Applicable e	earth*8	Rated current	Α	30	20	
lec	leakage bre	aker	Sensitivity of leak curr	rent mA	3	0	
Ш	Rated ope	rating cu	urrent*5	Α	12	6.8	
	Rated pov	ver cons	umption*5	kW (kVA)	3.8 (4.0)	4.0 (4.7)	
No	se level (Fr	ont 1 m/H	leight 1 m)*5	dB (A)	6		
Accessories					Alarm code list stickers 2 pcs. (English 1 pc./Japanese 1 pc.), Operation Manual (for installation/operation) 2 pcs. (English 1 pc./Japanese 1 pc.), Y-strainer (40 meshes) 25A, Barrel nipple 25A, Anchor bolt fixing brackets 2 pcs. (including 4 M10 bolts)* <sup>9</sup>		
We	ight (dry st	ate)		kg	Approx. 121		
*1 Use a 15% ethylene glycol aqueous solution if operating in a place where the ambient temperature and/or circulating fluid temperature is 10°C or less.				ng fluid temperature is 10°C or less			

\*1 Use a 15% ethylene glycol aqueous solution if operating in a place where the ambient temperature and/or circulating fluid temperature is 10°C or less.
 \*2 Use fluid in condition below as the circulating fluid. Tap water: Standard of The Japan Refrigeration And Air Conditioning Industry Association (JRA GL-02-1994) 15% ethylene glycol aqueous solution: diluted by tap water in condition above without any additives such as antiseptics.

15% ethylene glycol aqueous solution: dluide by tap water in condition above without any additives such as antiseptics.
Deionized water: Electric conductivity 1 µS/cm or higher (Electric resistivity 1 MΩ·cm or lower)
3 ① Facility water temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid temperature: 20°C, ④ Circulating fluid flow rate: Rated flow, ⑤ Power supply: 200/400 VAC
\*4 ① Facility water temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid flow rate: Rated flow, ④ Power supply: 200/400 VAC
\*5 ① Facility water temperature: 32°C, ② Circulating fluid: Tap water, ③ Circulating fluid temperature: 20°C, ④ Load: Same as the cooling capacity,
⑤ Circulating fluid flow rate: Rated flow, ⑥ Power supply: 200/400 VAC, ⑦ Piping length: Shortest
\*6 With the pressure control mode by inverter. When the pressure control mode is not used, the pump power frequency set mode can be used.
\*7 Fluid flow rate to maintain the cooling capacity. If the actual flow rate is lower than this, install a bypass piping.
\*8 To be prepared by the user. A specified earth leakage breaker is installed for option B [With earth leakage breaker], option S [Compliant with CE/UKCA, UL Standards] and 400 V type.
\*0 The and/or by the user. A specified earth leakage breaker is unsed to revise wood on exploration the option production definition to used the thore option above built or the option point.


\*9 The anchor bolt fixing brackets (including 4 M10 bolts) are used for fixing to wooden skids when packaging the thermo-chiller. No anchor bolt is included. \*10 The actual facility water flow rate will vary depending on the operating conditions.



### HRSH090 Series Inverter Type


#### **Cooling Capacity**

#### HRSH090-A -20-




\* If the product is used at an altitude of 1000 m or higher, refer to "Operating Environment/ Storage Environment" (page 305) Item 14 "For altitudes of 1000 m or higher."

#### HRSH090-A -40-




#### HRSH090-W -20/40-



#### Pump Capacity


#### HRSH090-0-20/40-0



### **A**Caution


#### **Mechanical Seal Pump**

The pump used for the thermo-chiller HRSH090 series uses a mechanical seal with the fixed ring and rotary ring used for the shaft seal part. If foreign matter enter the gap between the seals, this may cause a trouble such as leakage from the seal part or pump lock. Therefore, it is strongly recommended to install the particle filter in the return piping of the chiller.



### Thermo-chiller Inverter Type HRSH090 Series


#### Dimensions



### HRSH090 Series Inverter Type

#### **Recommended External Piping Flow**

External piping circuit is recommended as shown below.



No.	Description	Size	Recommended part no.	Note	
1	Valve	Valve Rc1/2 —		_	
2	Valve	Rc1	—	—	
3	Y-strainer Rc1 #40		Accessory	Install either the strainer or filter. If foreign matter with a size of 20 $\mu$ m	
3	Filter	Rc1 20 μm	HRS-PF005*1	or more are likely to enter, install the particle filter. For the recom- mended filter, refer to the optional accessory HRS-PF005 (page 300).	
4	Flow meter	Flow meter — — —		Prepare a flow meter with an appropriate flow range.	
5	Valve (Part of thermo-chiller)	Rc1/4	—	—	
6	Pressure gauge	0 to 1.0 MPa	—	—	
7	Y-strainer	Rc1/2 #40	—	Install either the strainer or filter. If foreign matter with a size of 20 $\mu$ m or more are likely to enter, select and pre-	
	Filter	Rc1/2 20 μm	—	pare a particle filter.	
8	Valve	Rc3/8	_	—	
9	Y-strainer	Rc3/8 #40	—	Install either the strainer or filter. If foreign matter with a size of 20 $\mu$ m or more are likely to enter, install the parti-	
9	Filter	Rc3/8 20 μm	FQ1011N-10-T020-B-X61*1	cle filter.	

\*1 The filter shown above cannot be directly connected to the thermo-chiller. Install it in the user's piping system.

#### **Cable Specifications**

Power supply and signal cable should be prepared by user.

#### **Power Cable Specifications**

	Rated value for t	hermo-chiller	Power cable examples		
Applicable model	Power supply	Applicable breaker rated current	Terminal block screw diameter	Cable size	Crimped terminal on the thermo- chiller side
HRSH090-□□-20	3-phase 200 VAC (50 Hz) 3-phase 200 to 230 VAC (60 Hz)	30 A		4 cores x 5.5 mm <sup>2</sup> (4 cores x AWG10) (Including grounding cable)	R5.5-5
HRSH090-□□-40	3-phase 380 to 415 VAC (50/60 Hz) 3-phase 460 to 480 VAC (60 Hz)	20 A	M5	3 x 5.5 mm <sup>2</sup> (3 x AWG10) (Power supply) 1 x 14 mm <sup>2</sup> (1 x AWG6) (Grounding cable)	R5.5-5 (Power supply) R14-5 (Grounding cable)

\* An example of the cable specifications is when two kinds of vinyl insulated wires with a continuous allowable operating temperature of 70°C at 600 V, are used at an ambient temperature of 30°C. Select the proper size of cable according to an actual condition.

#### **Signal Cable Specifications**

Terminal s	Cable specifications		
Terminal block screw diameter	Recommended crimped terminal	$0.75 \text{ mm}^2$ (A)M(C10)	
МЗ	Y-shape crimped terminal 1.25Y-3	0.75 mm <sup>2</sup> (AWG18) Shielded cable	

Signal cable

Power cable

**SMC** 

#### **Operation Display Panel**

The basic operation of this unit is controlled through the operation display panel on the front of the product.



No.	Description	Function				
110.	Description	Displays the size lating flyid surrant discharge temperature				
1	Digital display (7-segment,	PV	and pressure and alarm codes and other menu items (codes).			
	4 digits)	sv	V Displays the circulating fluid discharge temperature and the set values of other menus.			
2	[°C] [°F] lamp		upped with a unit conversion function. Displays the of displayed temperature (default setting: °C).			
3	[MPa] [PSI] lamp		upped with a unit conversion function. Displays the of displayed pressure (default setting: MPa).			
4	[REMOTE] lamp	Enables remote operation (start and stop) by communication. Lights up during remote operation.				
5	[RUN] lamp	Lights up when the product is started, and goes off when it is stopped. Flashes during stand-by for stop or anti-freezing function, or independent operation of the pump.				
6	[ALARM] lamp	Flashes with buzzer when alarm occurs.				
$\overline{\mathcal{O}}$	[ 🖃 ] lamp	Lights up when the surface of the fluid level indicator falls below the L level.				
8	[ 🕘 ] lamp	Equipped with a timer for start and stop. Lights up when this function is operated.				
9	[ O ] lamp	Equipped with a power failure auto-restart function, which restarts the product automatically after stopped due to a power failure. Lights up when this function is operated.				
10	[RUN/STOP] key	Makes the product start or stop.				
1	[MENU] key	Shifts the main menu (display screen of circulating fluid discharge temperature and pressure) and other menus (for monitoring and entry of set values).				
12	[SEL] key	Changes the item in menu and enters the set value.				
(13)	[▼] key	Decreases the set value.				
14)	[▲] key	Inci	eases the set value.			
15	[PUMP] key	Press the [MENU] and [RUN/STOP] keys simultaneously. The pump starts running independently to make the product ready for start-up (release the air).				
16	[RESET] key	Press the [▼] and [▲] keys simultaneously. The alarm buzzer is stopped and the [ALARM] lamp is reset.				

#### **List of Function**

	<b>–</b> <i>i</i>		
No.	Function	Outline	
1	Main display	Displays the current and set temperature of the circulating fluid, discharge pressure of the circulating fluid. Changes the circulating fluid set temperature.	
2	Alarm display menu	Indicates alarm number when an alarm occurs.	
3	Inspection monitor menu	Product temperature, pressure and accumulated operating time can be checked as daily inspection. Use these for daily inspection.	
4	Key-lock	Keys can be locked so that set values cannot be changed by operator error.	
5	Timer for operation start/stop	Timer is used to set the operation start/stop.	
6	Signal for the completion of preparation	A signal is output when the circulating fluid temperature reaches the set temperature, when using contact input/output and serial communication.	
7	Offset function	Use this function when there is a temperature offset between the discharge temperature of the thermo-chiller and user's equipment.	
8	Reset after power failure	Start operation automatically after the power supply is turned on.	
9	Key click sound setting	Operation panel key sound can be set on/off.	
10	Changing temp. unit	Temperature unit can be changed. Centigrade [°C] ⇔ Fahrenheit [°F]	
11	Changing pressure unit	Pressure unit can be changed. MPa $\Leftrightarrow$ PSI	
12	Data reset	Functions can be reset to the default settings (settings when shipped from the factory).	
13	Accumulation time reset	Reset function when the pump, the fan or the compressor is replaced. Reset the accumulated time here.	
14	Pump operation mode set	The fluid supply mode of the pump can be changed Pressure control mode $\Leftrightarrow$ Frequency set mode	
15	Anti-freezing function	Circulating fluid is protected from freezing during winter or at night. Set beforehand if there is a risk of freezing.	
16	Warming-up function	When circulating fluid temperature rising time at starting needs shortening during winter or at night, set beforehand.	
17	Alarm buzzer sound setting	Alarm sound can be set to on/off.	
18	Alarm customizing	Operation during alarm condition and threshold values can be changed depending on the alarm type.	
19	Communication	This function is used for contact input/output or serial communication.	

#### Alarm

This unit has alarms as standard, and displays each of them by its alarm code on the PV screen with the [ALARM] lamp ([LOW LEVEL] lamp) lit up on the operation display panel. The alarm can be read out through communication.

Code	Alarm message
AL01	Low level in tank
AL02	High circulating fluid discharge temp.
AL03	Circulating fluid discharge temp. rise
AL04	Circulating fluid discharge temp. drop
AL05	High circulating fluid return temp. (60°C)
AL06	High circulating fluid discharge pressure
AL07	Abnormal pump operation
AL08	Circulating fluid discharge pressure rise
AL09	Circulating fluid discharge pressure drop
AL10	High compressor intake temp.
AL11	Low compressor intake temp.
AL12	Low super heat temp.
AL13	High compressor discharge pressure
AL15	Refrigeration circuit pressure (high pressure side) drop
AL16	Refrigeration circuit pressure (low pressure side) rise
AL17	Refrigeration circuit pressure (low pressure side) drop

Code	Alarm message
AL18	Compressor running failure
AL19	Communication error
AL20	Memory error
AL21	DC line fuse cut
AL22	Circulating fluid discharge temp. sensor failure
AL23	Circulating fluid return temp. sensor failure
AL24	Compressor intake temp. sensor failure
AL25	Circulating fluid discharge pressure sensor failure
AL26	Compressor discharge pressure sensor failure
AL27	Compressor intake pressure sensor failure
AL28	Pump maintenance
AL29	Fan maintenance*1
AL30	Compressor maintenance
AL31	Contact input 1 signal detection
AL32	Contact input 2 signal detection
AL37	Compressor discharge temp. sensor failure

Alarm message	
Compressor discharge temp. rise	
Internal unit fan stoppage	
Dustproof filter maintenance*1	
Power stoppage	
Compressor waiting	
Fan breaker trip*1	
Fan inverter error*1	
Compressor breaker trip*2	
Compressor inverter error	
Pump breaker trip*2	
Pump inverter error	
Air exhaust fan stoppage*3	

1 Does not occur on the product of water-cooled refrigeration type.
 2 Does not occur on the product of power supply specification '-20'.
 3 Does not occur on the product of air-cooled refrigeration type.
 \* For details, read the Operation Manual.



### HRSH090 Series Inverter Type

#### **Communication Functions**

#### Contact Input/Output

Item		Specifications			
Connector type		M3 terminal block			
	Insulation method	Photocoupler			
	Rated input voltage	24 VDC			
Input signal	Operating voltage range	21.6 to 26.4 VDC			
	Rated input current	5 mA TYP			
	Input impedance	4.7 kΩ			
Contact cutnut	Rated load voltage	48 VAC or less/30 VDC or less			
Contact output signal	Maximum load current	500 mA AC/DC (Resistance load)			
orginal	Minimum load current	5 VDC 10 mA			
Οι	utput voltage	24 VDC $\pm 10\%$ 500 mA MAX (Not usable for inductive load)			
Circuit diagram		24 VDC output (500 mA MAX)*2 24 VCOM vertex 24 VCOM vertex 24 VCOM vertex 24 VCOM vertex 24 VCOM output 24 VCOM output 24 VCOM output 24 VCOM output 3 24 VCOM output 24 VCOM output 3 Contact input signal 2 Contact input signal 1 Contact output signal 3 Contact output signal 2 Contact output signal 3 Contact output signal 2 Contact output signal 3 Contact output signal 2 Contact output signal 3 Contact output signal 1 Contact output signal 1 C			


\*1 The pin numbers and output signals can be set by user. For details, refer to the Operation Manual, Communication function.

\*2 When using with optional accessories, depending on the accessory, the allowable current of 24 VDC devices will be reduced. Refer to the operation manual of the optional accessories for details.

#### **Serial Communication**

The serial communication (RS-485/RS-232C) enables the following items to be written and read out. For details, refer to the Operation Manual, Communication function.

Writing	F Readout
Run/Stop	Circulating fluid present temperature
Circulating fluid temperature	Circulating fluid discharge pressure
setting (SV)	Status information
	Alarm occurrence information
Li	ii



\* The terminal resistance of RS-485 (120 Ω) can be switched by the operation display panel. For details, refer to the Operation Manual, Communication function. Do not connect other than in the way shown above, as it can result in failure.

#### Please download the Operation Manual via our website, https://www.smcworld.com

# HRSH090 Series Options

 Options have to be selected when ordering the thermo-chiller.
 It is not possible to add them after purchasing the unit.

#### Option symbol

#### With Earth Leakage Breaker

#### HRSH090-00-20-B

#### With earth leakage breaker

A leakage breaker is built in to automatically stop the supply power when it has short-circuit, overcurrent or electrical leakage. (For models with power supply specification '-40', it is not necessary to select this option because an earth leakage breaker is equipped as standard.)

Applicable model	Rated current [A]	Sensitivity of leak current [mA]	Short circuit display method
HRSH090-□□-20-B	30	30	Mechanical button

#### \* 400 V type is equipped as standard.

(Refer to the specifications on pages 291, 292 and the dimensions on page 294 for details.)

#### Option symbol


With Automatic Fluid Fill Function

#### HRSH090-DD-J

#### • With automatic fluid fill function

By installing this at the automatic fluid fill port, the circulating fluid can be automatically supplied to the product using a built-in solenoid valve for a water fill while the circulating fluid is decreasing.

Applicable model	HRSH090-□□-□-J
Fluid fill method	Built-in solenoid valve for automatic water fill
Fluid fill pressure [MPa]	0.2 to 0.5
Feed water temperature [°C]	5 to 40



HRSH090-DD--M

Earth leakage breaker

#### Option symbol

Applicable to Deionized Water Piping

Compliant with CE/UKCA, UL Standards

HRSH090-□□-□-<u>M</u>

Option symbol

Applicable to deionized water piping Contact material of the circulating fluid circuit is made from non-copper materials.

ized water piping for circulating fluid Carbon, PP, PE, POM, FKM, NBR, EPDM, PVC, PTFE

Applicable model

\* No change in external dimensions

#### HRSH090-0-20-S Compliant with CE/UKCA, UL Standards Products compliant with CE/UKCA, UL Standards The following standards are applicable. Applicable standard Refer to the "Declaration of Conformity" on the SMC website. CE/UKCA marking 3054524 (UL61010-1) UL standard When selecting this option, · An earth leakage breaker with a breaker handle is equipped. Cannot be selected for 400 V type. (The breaker are the same as those for option B.) · A caution label is added. Cannot be selected together with option B. · The CE/UKCA, UL certification mark is added. Option symbol SI Unit Only

#### HRSH090-0-20-W

#### SI unit only

The circulating fluid temperature and pressure are displayed in SI units [MPa/°C] only.

If this option is not selected, a product with a unit selection function will be provided by default.

\* No change in external dimensions




# HRSH090 Series **Optional Accessories**

#### 1 Piping Conversion Fitting

This is a fitting to change the port from Rc to G or NPT.

- · Circulating fluid outlet, Circulating fluid return port Rc1  $\rightarrow$  NPT1 or G1
- · Drain port Rc1/4  $\rightarrow$  NPT1/4 or G1/4

(It is not necessary to purchase this when pipe thread type F or N is selected in "How to Order" since it is included in the product.)



When option J (With automatic fluid fill function) is included, use the following part numbers.  $\cdot$  Automatic fluid fill port Rc3/8  $\rightarrow$  NPT3/8 or G3/8

 $\cdot$  Overflow port Rc3/4  $\rightarrow$  NPT3/4 or G3/4

\* The conversion fittings for circulating fluid outlet/return port, drain port, facility water inlet/outlet (for water-cooled refrigeration) are also included.

2 pcs./set

Part no.	Contents	Applicable model		Part no.
HRS-EP020	NPT thread conversion fitting set	HRSH090-A-J		HRS-EP024
HRS-EP021	G thread conversion fitting set	HRSH090-A-J		HRS-EP025

#### ② Bypass Piping Set

When the circulating fluid goes below the minimum operating flow rate (as shown below), cooling capacity will be reduced and the temperature stability will be badly affected. Use the bypass piping set to ensure a circulating fluid flow rate of the minimum operating flow rate or more.


#### **Bypass Piping Set**


Part no.	Applicable model	Minimum operating flow rate [L/min]
HRS-BP005	HRSH090-00-0	20

#### **Bypass Piping Set (Stainless Steel)**

Part no.	Applicable model	Minimum operating flow rate [L/min]
HRS-BP011	HRSH090-□□-□	20

\* When selecting option "M," the HRS-BP011 is recommended.





Contents

NPT thread conversion fitting set

G thread conversion fitting set

Applicable model

HRSH090-W-J

#### Parts List


No.	Description	Fluid contact	Otv		
INO.	Description	HRS-BP005	HRS-BP011	Qty.	
1	Hose (I.D.: 15 mm)	PVC	PVC	1 (Approx. 700 mm)	
2	Outlet piping assembly (With globe valve)	Stainless steel, Brass, Bronze	Stainless steel	1	
3	Return piping assembly	Stainless steel, Brass	Stainless steel	1	
(4)	Nipple (Size: 1 inch)	Stainless steel	Stainless steel	4	
(5)	Union (Size: 1 inch)	Stainless steel	Stainless steel	2	
6	Sealant tape	PTFE	PTFE	1	
$\bigcirc$	Operation Manual	—		1	



### Optional Accessories HRSH090 Series

#### **③ Electric Conductivity Control Set**

The set indicates and controls the electric conductivity of the circulating fluid. Refer to the Operation Manual for details.



\*1 The product should be replaced when it can no longer preserve the electrical conductivity set value.

#### **④** Particle Filter Set

Removes foreign matter in the circulating fluid. If foreign matter such as scales in the piping enter the circulating fluid, this may cause the pump to malfunction. Therefore, it is strongly recommended to install the particle filter set. This set cannot be directly connected to the thermo-chiller. Install it in the user's piping system. For details, refer to the Operation Manual.

#### Parts List **Particle Filter Set** Description No. Material Qty. Note PC, PP HRS-PF005-H Fluid Tap water 1 Body 1 Element\*1 (2) PP 0.65 MPa Max. operating pressure 1 5 to 35°C (3) Conversion from NPT to Rc 2 Accessory Operating temperature range Extension piece Stainless steel Symbol (4) Accessory Nominal filtration accuracy 5 µm Handle 1 When -H is selected Nil None Installation environment Indoors (5) Sealant tape PTFE 1 н With handle \*1 The product should be replaced when the pressure drop reaches 0.1 MPa. (3 Rc1 **Replacement Element** HRS-PF006 The product should be replaced NPT1 when the pressure drop reaches NPT1 0.1 MPa (256) Rc1 2 343)

**SMC** 

300


### HRSH090 Series

#### **5** Filter for Circulating Fluid Fill Port

Prevents foreign matter from entering the tank when supplying the circulating fluid. Can be used just by fitting into the circulating fluid fill port.


### ■ Filter for circulating fluid fill port HRS-PF007

Material	Stainless steel 304, Stainless steel 316
Mesh size	200



#### 6 Drain Pan Set (With Water Leakage Sensor)

Drain pan for the thermo-chiller. Liquid leakage from the thermo-chiller can be detected by mounting the attached water leakage sensor. Align the drain pan with the hole in the bottom of the thermo-chiller for installation.



Parts List						
No.	Description					
1	Drain pan					
2	Water leakage sensor					
3	Extension cable Binding band (4 pcs.) Cable fixture (4 pcs.)					
4						
5						



#### **Wired Remote Controller**

When the wired remote controller is connected to the thermo-chiller, the operation start/stop setting or the set temperature can be changed from a place apart from the thermo-chiller. For details, refer to the Operation Manual.

#### Wired Remote Controller

#### HRS-CV004-1

Accessories				
Symbol	Symbol Accessories			
Nil	Nil None			
1	1With cable (Approx. 20 m)2With cable (Approx. 50 m)			
2				
3 With cable (Approx. 100 m)				



Wired remote controller **Displayed items Operable items** Circulating fluid discharge temperature Operation start/stop Circulating fluid discharge set temperature Circulating fluid temperature setting Circulating fluid discharge pressure Alarm sound stop B Circulating fluid electric conductivity\*1 Key-lock Circulating fluid flow rate Key operation sound ON/OFF Alarm code\*2 Digital display brightness adjustment Alarm sound ON/OFF \*1 Only when the electric conductivity control set is used. 29 \*2 Only when an alarm occurs. The alarm cannot be reset with the remote controller. Be sure to reset the alarm with the thermochiller main unit. 123 Thermo-chiller connection side 141 П Cable Wired remote controller connection side M12/4-core connector (socket side)

- \* To use the wired remote controller, the thermo-chiller main unit setting is needed.
- \* Use the wired remote controller indoors.
- $\ast$  Pass the cable through the duct, etc. so that it is not exposed to rain water or direct sunlight.

# HRSH090 Series Cooling Capacity Calculation

#### **Required Cooling Capacity Calculation**

#### Example 1: When the heat generation amount in the user's equipment is known.

The heat generation amount can be determined based on the power consumption or output of the heat generating area — i.e. the area requiring cooling — within the user's equipment.\*1

#### $(\ensuremath{\underline{1}})$ Derive the heat generation amount from the power consumption.

Power consumption P: 7 [kW]

Cooling capacity = Considering a safety factor of 20%, 7 [kW] x 1.2 = 8.4 [kW]

② Derive the heat generation amount from the power supply output.

Power supply output VI: 8.8 [kVA]


 $Q = P = V \times I \times Power factor$ 

In this example, using a power factor of 0.85:

= 8.8 [kVA] x 0.85 = 7.5 [kW]

Cooling capacity = Considering a safety factor of 20%,

#### 7.5 [kW] x 1.2 = 9.0 [kW]



**③** Derive the heat generation amount from the output.

Output (shaft power, etc.) W: 13 [kW]

$$Q = P = \frac{W}{Efficiency}$$

In this example, using an efficiency of 0.7:

-

Cooling capacity = Considering a safety factor of 20%,

7.3 [kW] x 1.2 = 8.8 [kW]

\*1 The examples above calculate the heat generation amount based on the power consumption. The actual heat generation amount may differ due to the structure of the user's equipment. Be sure to check it carefully.

#### Example 2: When the heat generation amount in the user's equipment is not known.

#### Obtain the temperature difference between inlet and outlet by circulating the circulating fluid inside the user's equipment.

Heat generation amount by user's equipment Q	: Unknown [W] ([J/s])
Circulating fluid	: Tap water*1
Circulating fluid mass flow rate <b>qm</b>	: (= ρ x <b>qv</b> ÷ 60) [kg/s]
Circulating fluid density p	: 1 [kg/L]
Circulating fluid (volume) flow rate <b>qv</b>	: 35 [L/min]
Circulating fluid specific heat C	: 4.186 x 10 <sup>3</sup> [J/(kg·K)]
Circulating fluid outlet temperature T1	: 293 [K] (20 [°C])
Circulating fluid return temperature T2	: 296 [K] (23 [°C])
Circulating fluid temperature difference $\Delta T$	: 3 [K] (= <b>T</b> 2 – <b>T</b> 1)
Conversion factor: minutes to seconds (SI units)	: 60 [s/min]


\*1 Refer to page 304 for the typical physical property value of tap water or other circulating fluids.


$$\mathbf{Q} = \mathbf{qm} \mathbf{x} \mathbf{C} \mathbf{x} (\mathbf{T}_2 - \mathbf{T}_1)$$
  
o x qv x C x  $\Delta \mathbf{T}$ 

$$=\frac{\rho x q v x C x \Delta T}{60} = \frac{1 x 35 x 4.186 x 10^3 x 3.0}{60}$$

= 7325 [J/s] 
$$\approx$$
 7325 [W] = 7.3 [kW]

Cooling capacity = Considering a safety factor of 20%,





Example of conventional units (Reference) Heat generation amount by user's equipment  $\textbf{Q}: Unknown \; [cal/h] \rightarrow [W]$ Circulating fluid : Tap water\*1 Circulating fluid weight flow rate **qm** : (=  $\rho \times qv \times 60$ ) [kgf/h] Circulating fluid weight volume ratio  $\gamma$  : 1 [kgf/L] Circulating fluid (volume) flow rate qv : 35 [L/min] Circulating fluid specific heat C : 1.0 x 10<sup>3</sup> [cal/(kgf·°C)] Circulating fluid outlet temperature T1 : 20 [°C] Circulating fluid return temperature T2: 23 [°C] Circulating fluid temperature difference  $\Delta T$  : 3 [°C] (= T<sub>2</sub> - T<sub>1</sub>) Conversion factor: hours to minutes : 60 [min/h] Conversion factor: kcal/h to kW : 860 [(cal/h)/W]  $Q = \frac{qm \ x \ C \ x \ (T_2 - T_1)}{qm \ x \ C \ x \ (T_2 - T_1)}$ 860 <u>- γ x qv x 60 x</u> C x ΔT 860 1 x 35 x 60 x 1.0 x 10<sup>3</sup> x 3.0 860 ≈ 7325 [W] = 7.3 [kW] Cooling capacity = Considering a safety factor of 20%, 7.3 [kW] x 1.2 = 8.8 [kW]


303

**SMC** 

### Cooling Capacity Calculation HRSH090 Series

#### Required Cooling Capacity Calculation

#### Example 3: When there is no heat generation, and when cooling the object below a certain temperature and period of time.



#### Precautions on Cooling Capacity Calculation

#### 1. Heating capacity

When the circulating fluid temperature is set above room temperature, it needs to be heated by the thermo-chiller. The heating capacity depends on the circulating fluid temperature. Consider the radiation rate and heat capacity of the user's equipment and check beforehand if the required heating capacity is provided.

#### 2. Pump capacity

#### <Circulating fluid flow rate>

Circulating fluid flow rate varies depending on the circulating fluid discharge pressure. Consider the installation height difference between the thermo-chiller and the user's equipment, and the piping resistance such as circulating fluid pipings, or piping size, or piping curves in the machine. Check beforehand if the required flow is achieved, using the pump capacity curves.

#### <Circulating fluid discharge pressure>

Circulating fluid discharge pressure has the possibility to increase up to the maximum pressure in the pump capacity curves. Check beforehand if the circulating fluid pipings or circulating fluid circuit of the user's equipment are fully durable against this pressure.

#### Circulating Fluid Typical Physical Property Values

#### 1. This catalog uses the following values for density and specific heat in calculating the required cooling capacity. Density $\rho$ : 1 [kg/L] (or, using conventional units, weight volume ratio $\gamma = 1$ [kg/L])

Specific heat C: 4.19 x 103 [J/(kg·K)] (or, using conventional units, 1 x 103 [cal/(kgf·°C)])

#### 2. Values for density and specific heat change slightly according to temperature shown below. Use this as a reference.

Water						
Physical property			Conventional units			
Temperature	[kg/L]	[J/(kg·K)]	Weight volume ratio $\gamma$ [kgf/L]	Specific heat C [cal/(kgf.°C)]		
5°C	1.00	4.2 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
10°C	1.00	4.19 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
15°C	1.00	4.19 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
20°C	1.00	4.18 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
25°C	1.00	4.18 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
30°C	1.00	4.18 x 10 <sup>3</sup>	1.00	1 x 10 <sup>3</sup>		
35°C	0.99	4.18 x 10 <sup>3</sup>	0.99	1 x 10 <sup>3</sup>		
40°C	0.99	4.18 x 10 <sup>3</sup>	0.99	1 x 10 <sup>3</sup>		

#### 15% Ethylene Glycol Aqueous Solution

Physical property		Specific heat C	Conventional units		
Temperature	[kg/L]	[J/(kg·K)]	Weight volume ratio $\gamma$ [kgf/L]	Specific heat C [cal/(kgf.°C)]	
5°C	1.02	3.91 x 10 <sup>3</sup>	1.02	0.93 x 10 <sup>3</sup>	
10°C	1.02	3.91 x 10 <sup>3</sup>	1.02	0.93 x 10 <sup>3</sup>	
15°C	1.02	3.91 x 10 <sup>3</sup>	1.02	0.93 x 10 <sup>3</sup>	
20°C	1.01	3.91 x 10 <sup>3</sup>	1.01	0.93 x 10 <sup>3</sup>	
25°C	1.01	3.91 x 10 <sup>3</sup>	1.01	0.93 x 10 <sup>3</sup>	
30°C	1.01	3.91 x 10 <sup>3</sup>	1.01	0.94 x 10 <sup>3</sup>	
35°C	1.01	3.91 x 10 <sup>3</sup>	1.01	0.94 x 10 <sup>3</sup>	
40°C	1.01	$3.92 \times 10^3$	1.01	$0.94 \times 10^3$	

Shown above are reference values. Contact circulating fluid supplier for details.





Be sure to read this before handling the products. Refer to page 605 for safety instructions and pages 606 to 609 for temperature control equipment precautions.

#### Design

### \land Warning

- 1. This catalog shows the specifications of a single unit.
  - 1. Check the specifications of the single unit (contents of this catalog) and thoroughly consider the adaptability between the user's system and this unit.
  - 2. Although a protection circuit as a single unit is installed, prepare a drain pan, water leakage sensor, discharge air facility, and emergency stop equipment, depending on the user's operating conditions. Also, the user is requested to carry out a safety design for the whole system.

# 2. When attempting to cool areas that are open to the atmosphere (tanks, pipes), plan your piping system accordingly.

When cooling open-air external tanks, arrange the piping so that there are coil pipes for cooling inside the tanks and to carry back the entire flow volume of circulating fluid that is released.

### 3. Use non-corrosive materials for circulating fluid contact parts.

The recommended circulating fluid is tap water or 15% ethylene glycol aqueous solution. Using corrosive materials such as aluminum or iron for fluid contact parts such as piping may cause clogging or leakage in the circulating fluid circuit. Therefore, take sufficient care when selecting fluid contact part materials such as piping.

4. Design the piping so that no foreign matter enters the chiller.

If foreign matter, such as scales in the piping, enters the circulating fluid, this may cause the pump to malfunction. Therefore, it is strongly recommended to install the particle filter.

5. The facility water outlet temperature (water-cooled type) may increase up to around 60°C.

When selecting the facility water pipings, consider the suitability for temperature.

Selection

### \land Warning

#### Model selection

When selecting a thermo-chiller model, the amount of heat generation from the user's equipment must be known. Obtain this value, referring to "Cooling Capacity Calculation" on pages 303 and 304 before selecting a model.

Handling

### \land Warning

#### Thoroughly read the operation manual.

Read the operation manual completely before operation, and keep the manual where it can be referred to as necessary.

#### **Operating Environment/Storage Environment**

### \land Warning

### 1. Do not use in the following environment as it will lead to a breakdown.

- 1. Outdoors
- 2. In locations where water, water vapor, salt water, and oil may splash on the product.
- 3. In locations where there are dust and particles.
- 4. In locations where corrosive gases, organic solvents, chemical fluids, or flammable gases are present. (This product is not explosion proof.)
- 5. In locations where the ambient temperature/humidity exceeds the limits as mentioned below or where condensation occurs. During transportation/storage: -15°C to 50°C, 15% to 85%

(But as long as water or circulating fluid are not left inside the pipings)

During operation: 5°C to 45°C, 30% to 70%

- (However, use a 15% ethylene glycol aqueous solution if operating in a place where the ambient temperature or circulating fluid temperature is 10°C or less.)
- 6. In locations where condensation may occur.
- 7. In locations which receive direct sunlight or radiated heat.
- 8. In locations where there is a heat source nearby and the ventilation is poor.
- 9. In locations where temperature substantially changes.
- In locations where strong magnetic noise occurs. (In locations where strong electric fields, strong magnetic fields and surge voltage occur.)
- 11. In locations where static electricity occurs, or conditions which make the product discharge static electricity.
- 12. In locations where high frequency occurs.
- 13. In locations where damage is likely to occur due to lightning.
- 14. In locations at an altitude of 3000 m or higher (Except
  - during storage and transportation)
  - For altitudes of 1000 m or higher Because of lower air density, the heat radiation efficiencies of the devices in the product will be lower in the location at an altitude of 1000 m or higher. Therefore, the maximum ambient temperature to use and the cooling capacity will lower according to the descriptions in the table below.

Select the thermo-chiller considering the descriptions.

- ① Upper limit of ambient temperature: Use the product in ambient temperature of the described value or lower at each altitude.
- ② Cooling capacity coefficient: The product's cooling capacity will lower to one that multiplied by the described value at each altitude.

Altitude [m]	① Upper limit of ambient temperature [°C]	② Cooling capacity coefficient	
Less than 1000 m	45	1.00	
Less than 1500 m	42	0.85	
Less than 2000 m	38	0.80	
Less than 2500 m	35	0.75	
Less than 3000 m	32	0.70	

- 15. In locations where strong impacts or vibrations occur.
- In locations where a massive force strong enough to deform the product is applied or a weight from a heavy object is applied.
- 17. In locations where there is not sufficient space for maintenance.
- 18. Bevelled place
- 19. Insects or plants may enter the unit.
- 2. The product is not designed for clean room usage. It generates particles internally.





Be sure to read this before handling the products. Refer to page 605 for safety instructions and pages 606 to 609 for temperature control equipment precautions.

Transportation/Carriage/Movement


### \land Warning

- 1. This product is heavy. Pay attention to safety and the position of the product when it is transported, carried, and moved.
- 2. Read the operation manual carefully before moving the product after unpacking.

### ▲ Caution

1. Never put the product down on its side as this may cause a failure.


The product will be delivered in the packaging shown below.



Model	Weight [kg]	Dimensions [mm]
HRSH090-A-20/40 165		Height 1320 x Width 580 x Depth 1240
HRSH090-W-20/40	156	

#### 2. Transporting with forklift

- 1. A licensed driver should drive the forklift.
- 2. Insert the fork to the place specified on the label. The fork should reach through to the other side of the product.
- 3. Be careful not to bump the fork to the cover panel or piping ports.



#### 3. Transporting with casters

- 1. This product is heavy and should be moved by at least two people to avoid falling.
- 2. Do not grip the piping port on the back side or the handles of the panel.
- 3. Do not pass over bumps, etc. with the casters.

### ▲ Caution

If this product is to be transported after delivery, please use the original packaging the product was delivered in. If other packaging is to be used, carefully package the product so as to prevent the product from incurring any damage during transport.

#### Installation

### \land Warning

- 1. Do not use the product outdoors.
- 2. Do not place heavy objects on top of this product, or step on it.


The external panel can be deformed and danger can result.

### \land Caution

- 1. Install on a rigid floor which can withstand this product's weight.
- 2. Refer to the operation manual for this product, and secure an installation space that is necessary for the maintenance and ventilation.

#### <Air-cooled refrigeration>

- The air-cooled type product exhausts heat using the fan that is mounted to the product. If the product is operated with insufficient ventilation, ambient temperature may exceed 45°C, and this will affect the performance and life of the product. To prevent this ensure that suitable ventilation is available (see below).
- 2. For installation indoors, ventilation ports and a ventilation fan should be equipped as needed.



3. If it is impossible to exhaust heat from the installation area indoors, or when the installation area is conditioned, provide a duct for heat exhaustion to the air outlet port of this product for ventilation. Do not mount the inlet of the duct (flange) directly to the air vent of the product, and keep a space larger than the diameter of the duct. Additionally, consider the resistance of the duct when making the air vent port for the duct.

#### <Heat radiation amount/Required ventilation rate>

	Heat	Required ventilation rate [m3/min]		
Model	radiation amount	Differential temp. of 3°C between inside and outside	Differential temp. of 6°C between inside and outside	
	[kW]	of installation area	of installation area	
HRSH090-A-20/40	Approx. 18	305	155	





Be sure to read this before handling the products. Refer to page 605 for safety instructions and pages 606 to 609 for temperature control equipment precautions.

Piping

### **A** Caution

1. The circulating fluid and facility water piping should be prepared by the customer with consideration of the operating pressure, temperature, and circulating fluid/facility compatibility.

If the operating performance is not sufficient, the pipings may burst during operation. Also, the use of corrosive materials such as aluminum or iron for fluid contact parts, such as piping, may not only lead to clogging or leakage in the circulating fluid and facility water circuits but also refrigerant leakage and other unexpected problems. Provide protection against corrosion when you use the product.

- **2. Select the piping port size which can exceed the rated flow.** For the rated flow, refer to the pump capacity table.
- 3. When tightening at the drain port of this product, use a pipe wrench to clamp the connection ports.
- 4. For the circulating fluid piping connection, install a drain pan and wastewater collection pit just in case the circulating fluid may leak.
- 5. This product series are constant-temperature fluid circulating machines with built-in tanks.

Do not install equipment on your system side such as pumps that forcibly return the circulating fluid to the unit. Also, if you attach an external tank that is open to the air, it may become impossible to circulate the circulating fluid. Proceed with caution.

6. The facility water flow rate is adjusted automatically according to the operating conditions.

In addition, the facility water return temperature is 60°C at maximum.

#### **Circulating Fluid**

### **A** Caution

- 1. Avoid oil or other foreign matter entering the circulating fluid.
- 2. When water is used as a circulating fluid, use tap water that conforms to the appropriate water quality standards. Use tap water that conforms to the standards shown below (including water used for dilution of ethylene glycol aqueous solution).

#### Tap Water (as a Circulating Fluid) Quality Standards The Japan Refrigeration and Air Conditioning Industry Association

JRA GL-02-1994 "Cooling water system – Circulation type – Make-up water"

	Item Unit Standard value		Influence		
	liem	Unit	Standard value	Corrosion	Scale generation
	pH (at 25°C)	—	6.0 to 8.0	0	0
F	Electric conductivity (25°C)	[µS/cm]	100*1 to 300*1	0	0
item	Chloride ion (CI-)	[mg/L]	50 or less	0	
	Sulfuric acid ion (SO <sub>4</sub> <sup>2–</sup> )	[mg/L]	50 or less	0	
Standard	Acid consumption amount (at pH4.8)	[mg/L]	50 or less		0
tar	Total hardness	[mg/L]	70 or less		0
S	Calcium hardness (CaCO <sub>3</sub> )	[mg/L]	50 or less		0
	Ionic state silica (SiO <sub>2</sub> )	[mg/L]	30 or less		0
item	Iron (Fe)	[mg/L]	0.3 or less	0	0
	Copper (Cu)	[mg/L]	0.1 or less	0	
Ce	Sulfide ion (S <sub>2</sub> -)	[mg/L]	Should not be detected.	0	
Reference	Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	[mg/L]	0.1 or less	0	
efe	Residual chlorine (Cl)	[mg/L]	0.3 or less	Ó	
ď	Free carbon (CO <sub>2</sub> )	[mg/L]	4.0 or less	Ó	

\*1 In the case of [M $\Omega$ ·cm], it will be 0.003 to 0.01.

O: Factors that have an effect on corrosion or scale generation.
 Even if the water quality standards are met, complete prevention of corrosion is not guaranteed.

- 3. Use an ethylene glycol aqueous solution that does not contain additives such as preservatives.
- 4. When using ethylene glycol aqueous solution, maintain a maximum concentration of 15%. Overly high concentrations can cause a pump overload.

Low concentrations, however, can lead to freezing when circulating fluid temperature is 10°C or lower and cause the thermo-chiller to break down.

#### **Circulating Fluid**

### \land Caution

5. When deionized water is used, the electric conductivity should be 1  $\mu$ S/cm or higher (Electric resistivity: 1 M $\Omega$ ·cm or lower).


**Electrical Wiring** 

### \land Warning

Grounding should never be connected to a water line, gas line or lightning rod.

### ▲ Caution


- 1. Power supply and communication cables should be prepared by user.
- Provide a stable power supply which is not affected by surge or distortion.
   If the voltage increase ratio (dV/dt) at the zero cross should exceed 40 V/200 μsec., it may result in malfunction.



#### <For option B [With earth leakage breaker]>

### 3. This product is installed with a breaker with the following operating characteristics.

For the user's equipment (inlet side), use a breaker whose operating time is equal to or longer than the breaker of this product. If a breaker with shorter operating time is connected, the user's equipment could be cut off due to the inrush current of the motor of this product.



**Facility Water Supply** 

### \land Warning

SMC

#### <Water-cooled refrigeration>

1. The water-cooled refrigeration type thermo-chiller radiates heat to the facility water. Prepare the facility water system that satisfies the heat radiation and the facility water specifications below.

#### Required facility water system <Heat radiation amount/Facility water specifications>

		•
Model	Heat radiation [kW]	Facility water specifications
HRSH090-W□-□	Approx. 20	Refer to "Facility water system" in the specifications on page 292.



Be sure to read this before handling the products. Refer to page 605 for safety instructions and pages 606 to 609 for temperature control equipment precautions.

#### **Facility Water Supply**

### \land Warning

2. When using tap water as facility water, use tap water that conforms to the appropriate water quality standards. Use tap water that conforms to the standards shown below.

If the water quality standards are not met, clogging or leakage in the facility water piping, or other problems such as refrigerant leakage, etc., may result.

#### Tap Water (as Facility Water) Quality Standards

The Japan Refrigeration and Air Conditioning Industry Association JRA GL-02-1994 "Cooling water system – Circulation type – Make-up water"

	Item	Unit	Unit Standard value		Influence	
	item	Unit	Standard value	Corrosion	Scale generation	
Standard item	pH (at 25°C)	—	6.5 to 8.2	0	0	
	Electric conductivity (25°C)	[µS/cm]	100*1 to 800*1	0	0	
	Chloride ion (CI-)	[mg/L]	200 or less	0		
	Sulfuric acid ion (SO42-)	[mg/L]	200 or less	0		
	Acid consumption amount (at pH4.8)	[mg/L]	100 or less		0	
	Total hardness	[mg/L]	200 or less		0	
	Calcium hardness (CaCO <sub>3</sub> )	[mg/L]	150 or less		0	
	Ionic state silica (SiO <sub>2</sub> )	[mg/L]	50 or less		0	
Reference item	Iron (Fe)	[mg/L]	1.0 or less	0	0	
	Copper (Cu)	[mg/L]	0.3 or less	0		
	Sulfide ion $(S_2^-)$	[mg/L]	Should not be detected.	0		
	Ammonium ion (NH <sub>4</sub> +)	[mg/L]	1.0 or less	0		
	Residual chlorine (Cl)	[mg/L]	0.3 or less	Ó		
æ	Free carbon (CO <sub>2</sub> )	[mg/L]	4.0 or less	0		

\*1 In the case of [M $\Omega$ ·cm], it will be 0.001 to 0.01.

• O: Factors that have an effect on corrosion or scale generation.

• Even if the water quality standards are met, complete prevention of corrosion is not guaranteed.

# 3. Set the supply pressure between 0.3 to 0.5 MPa. Ensure a pressure difference at the facility water inlet/outlet of 0.3 MPa or more.

If the supply pressure is high, it will cause water leakage. If the supply pressure and pressure difference at the facility water inlet/outlet is low, it will cause an insufficient flow rate of the facility water, and poor temperature control.

#### Operation

### \land Warning

#### 1. Confirmation before operation

- The fluid level of a tank should be within the specified range of H (High) and L (Low). When exceeding the specified level, the circulating fluid will overflow.
- 2) Remove the air.

Conduct a trial operation, looking at the fluid level. Since the fluid level will go down when the air is removed from the user's piping system, supply water once again when the fluid level is reduced. When there is no reduction in the fluid level, the job of removing the air is completed. Pump can be operated independently.

#### 2. Confirmation during operation

• Check the circulating fluid temperature.

The operating temperature range of the circulating fluid is between 5 and  $40^{\circ}$ C.

When the amount of heat generated from the user's equipment is greater than the product's capability, the circulating fluid temperature may exceed this range. Use caution regarding this matter.

#### 3. Emergency stop method

• When an abnormality is confirmed, stop the machine immediately. After stopping operation, disconnect the power supply from the user's equipment. **Operation Restart Time/Operation and Suspension Frequency** 

### \land Caution

- 1. Wait five minutes or more before restarting operation after it has been stopped. If the operation is restarted within five minutes, the protection circuit may activate and the operation may not start properly.
- 2. Operation and suspension frequency should not exceed 10 times per day. Frequently switching between operation and suspension may result in the malfunction of the refrigeration circuit.

#### **Protection Circuit**

### ▲ Caution

If operating in the below conditions, the protection circuit will activate and an operation may not be performed or will stop.

- $\bullet$  Power supply voltage is not within the rated voltage range of  $\pm 10\%.$
- In case the water level inside the tank is reduced abnormally.
- Circulating fluid temperature is too high.
- Compared to the cooling capacity, the heat generation amount of the user's equipment is too high.
- Ambient temperature is too high. (Check the ambient temperature in the specifications.)
- Ventilation hole is clogged with dust or dirt.

#### Maintenance

### A Caution

#### <Periodical inspection every one month> Clean the ventilation hole.

If the dustproof filter of water-cooled type product becomes clogged with dust or debris, a decline in cooling performance can result. In order to avoid deforming or damaging the dustproof filter, clean it with a long-haired brush or air gun.

#### <Periodical inspection every three months> Inspect the circulating fluid.

1. When using tap water or deionized water

- Replacement of circulating fluid
  - Failure to replace the circulating fluid can lead to the development of bacteria or algae. Replace it regularly depending on your usage conditions.
- Tank cleaning (same as the HRS series) Consider whether dirt, slime or foreign matter may be present in the circulating fluid inside the tank, and carry out regular cleanings of the tank.
- 2. When using ethylene glycol aqueous solution Use a concentration meter to confirm that the concentration does not exceed 15%.

Dilute or add as needed to adjust the concentration.

#### <Periodical inspection during the winter season>

**1. Make water-removal arrangements beforehand.** If there is a risk of the circulating fluid and facility water freezing when the product is stopped, release the circulating fluid and facility water in advance.

#### 2. Consult a professional.

This product has an "anti-freezing function" and "warming-up function." Read the operation manual carefully, and if any additional anti-freezing function (e.g. tape heater) is needed, ask for it from the vendor.





Be sure to read this before handling the products. Refer to page 605 for safety instructions and pages 606 to 609 for temperature control equipment precautions.

Refrigerant with GWP reference								
	Global warming potential (GWP)							
Refrigerant	Regulation (EU) No 517/2014 (Based on the IPCC AR4)	Fluorocarbon Emissions Control Act (Japan)						
		GWP value labeled on products	GWP value to be used for reporting the calculated amount of leakage					
R134a	1,430	1,430	1,300					
R404A	3,922	3,920	3,940					
R407C	1,774	1,770	1,620					
R410A	2,088	2,090	1,920					

\* This product is hermetically sealed and contains fluorinated greenhouse gases (HFC). When this product is sold on the market in the EU after January 1, 2017, it needs to be compliant with the quota system of the F-Gas Regulation in the EU.

\* See specification table for refrigerant used in the product.