

With One-touch fittings are newly introduced.








Elbow type



2-color digital display allows you to choose the setting according to your application requirements. 4 different display settings are available.




Abnormal conditions can be detected at a glance!





With One-touch fitting (Ø4, Ø6, Ø5/32", Ø1/4")

Reduced dimensions in piping direction




* Comparison when One-touch fittings (KQ2H06-M5 / KQ2L06-M5) are connected to the piping ports (M5 x 0.8)



Space-saving improvement

Economical use of space



With analog output

In addition to the conventional voltage output type (1 to 5 $^{\rm V}$)

Current output type (4 to 20 mA) is now available.

- Convenient when longer wiring is required
- Excellent noise resistance


Switches for vacuum and positive pressure can be easily distinguished.

The different display panel frame colors easily tell them apart.







Display calibration



More user-friendly controls



Raised rubber button controls are clearly set apart, simple to operate, soft to the touch.



Plug-type connectors take the burden out of wiring work and maintenance.

High-precision resolution: 1/1000

Variations

		Vacuum/Low pressure ZSE30	Positive pressure ISE30	
Rated pressure range		100 kPa 	1 MPa 0	
Setting/Display resolution		0.2 kPa 0.001 MPa		
Output	Switch output NPN/PNP open collector (1 ou		ollector (1 output)	
Output	Analog output	Voltage output: 1 to 5 V; Current output: 4 to 20 m/		
Current consumption		45 mA or less (70 mA or less for current output)		
Option		Panel mount/Bracket		



PSE

rSE3 PS

ZSE₂

ZSP

ISA2

IS□


ZSM

PF2□

IF□ Data



How to Order



When optional parts are required separately, use the following part numbers to place an order.

Option	Part no.	Note
Lead wire with connector	ZS-27-A	Lead wire length: 2 m
Bracket	ZS-27-B	With mounting screws (M3 x 5L: 2 pcs.)
Panel mount adapter	ZS-27-C	With M3 x 8L (2 pcs.)
Panel mount adater + Front protective cover	ZS-27-D	With M3 x 8L (2 pcs.)

Nil	With unit switching function
M	Fixed SI unit (International System of Units) Note)

Note) Fixed unit:

For vacuum/Low pressure: kPA For positive pressure: MPa

Specifications



			ZSE30 (Vacuum/Low pressure)	ISE30 (Positive pressure)	
Rated pressure range		sure range	-100.0 to 100.0 kPa	0.000 to 1.000 MPa	
Regulating pressure range		pressure range	-101.0 to 101.0 kPa	-0.100 to 1.000 MPa	
Proof pressure		sure	500 kPa	1.5 MPa	
Min. re	gula	iting unit	0.2 kPa	0.001 MPa	
Fluid			Air, Inert gas, Non-flammable gas		
Power	sup	ply voltage	12 to 24 VDC, Ripple (p-p) 10% or less (With power supply polarity protection)		
Curren	nt co	nsumption	45 mA or less (at no load)		
Switch	out	out Note 1)	NPN or PNP open col	lector output: 1 output	
		Max. load current	80	mA	
		Max. applied voltage	30 V (With 1	NPN output)	
		Residual voltage	1 V or less (With load current of 80 mA)		
		Response time	2.5 ms or less (Response time selections with anti-chattering function: 20, 160, 640, 1280 ms		
		Short circuit protection	Yes		
Repeat	tabil	ity	±0.2% F.S. ±2 digit or less	±0.2% F.S. ±1 digit or less	
Analog output		Voltage output Note 2)	Output voltage: 1 to 5 V ±2.5% F.S. or less (With rated pressure range) Linearity: ±1% F.S. or less, Output impedance: Approx. 1 kΩ		
		Current output Note 3)	Output current: 4 to 20 mA $\pm 2.5\%$ F.S. or less (With rated pressure range Linearity: $\pm 1\%$ F.S. or less Maximum load impedance: 300 Ω with power supply voltage of 12 V 600 Ω with power supply voltage of 24 V Minimum load impedance: 50 Ω		
Hyster	aeie	Hysteresis mode	Adjustable (can be set from 0)		
riystere		Window comparator mode	Adjustable (can be set from 0)		
Display			3 1/2 digit, 7-segment indicator, 2-color display (Red and green) Sampling cycle: 5 times/s		
Display accuracy		curacy	±2% F.S. ±2 digit (at 25°C ambient temperature)	±2% F.S. ±1 digit (at 25°C ambient temperature)	
Indicat	or lig	ght	Light up when output is ON (Green)		
Tempe	ratu	re characteristics	±2% F.S. or less (based on 25°C)		
		osure	IP40		
nental Se do	Operating temperature range		Operating: 0 to 50°C, Stored: -10 to 60°C (No freezing or condensation)		
	Operating humidity range		Operating and stored: 35 to 85% RH (No condensation)		
	With	stand voltage	1000 VAC for 1 min. between live parts and enclosure		
resista Insu		ation resistance	$50 \text{ M}\Omega$ or more between live parts and enclosure (at 500 VDC)		
		ation resistance	10 to 150 Hz, 1.5 mm or 20 m/s ² amplitude in X, Y, Z directions for 2 hours each		
	Impact resistance		100 m/s² in X, Y, Z directions 3 times each		
Standard			Compliant with CE Marking and UL (CSA) standards		
Note 1) When switch output is sele			cted, analog output is not available.		

Note 1) When switch output is selected, analog output is not available.

Note 2) When voltage output is selected, a simultaneous selection of switch output and current output is not available.

Note 3) When current output is selected, a simultaneous selection of switch output and voltage output is not available.

Piping Specifications

Part		01	T1	C4H	C6H	N7H	C4L	C6L	N7L
		R 1/8 M5 x 0.8	NPT 1/8 M5 x 0.8	_	_	_	_		_
Port size	One-touch fitting Straight type	_	_	ø4 mm ø5/32 inch	ø6 mm	ø1/4 inch	_	_	_
	One-touch fitting Elbow type	_	_	_	_	_	ø4 mm ø5/32 inch	ø6 mm	ø1/4 inch
		Sensor pressure receiving area: Silicon, Piping port: C3602 (Electroless nickel plated), O-ring: HNBR							
vveiled	I part material			O-ring: NBR		O-ring: NBR, fitting: PBT			
Mai ala	With lead wire with connector (2 m)	81 g		76 g		78 g			
Weight	Without lead wire with connector	43 g		38 g		40 g			

PSE

ZSE3

ZSE1

ZSP

ISA2

IS□


ZSM

PF2□

 $\mathsf{IF}\square$

Data

Setting



Initial Setting

Initial setting mode

Press and hold the SET button for 2 seconds or longer. Display monitor will be per Figure A below, and the switch will now be in the display color setting mode.




Figure A

If the unit specification indicated at the time of ordering is "M", the fixed SI unit will be used. If it is Nil, refer to "Unit Switching Function" on page 16-2-8.

1. Display color setting

Select the color for LCD display. Press the $\triangle UP$ or $\nabla DOWN$ button to choose a display color.



Press the SET button to set the color and proceed to the operating mode setting.


ON/OFF: Green

If the analog output is set, press the $\triangle UP$ or $\nabla DOWN$ button and select the desired display color from Ling (Green) or red (Red). Press the SET button to exit this mode and return to the measuring mode.

2. Operating mode setting

ON/OFF: Red

This mode will let you select the switch operating mode. While the current operating mode is displayed, press the △UP or ∇DOWN button to select a newly desired operating




Press the SET button to set the mode and proceed to the output type setting.

3. Output type setting

The type of switch output can be set arbitrarily. While the current output type is displayed, press the ∇DOWN button to switch between normally open no and normally closed n[.





Normally open

Normally closed

Press the SET button to set the output type and proceed to the response time setting.

4. Response time setting

The switch output response time can be set arbitrarily. Chattering can be prevented with a response time setting. While the current response time is displayed, press the $\triangle UP$ or ∇ DOWN button to select a new response time.







2.5 ms

20 ms

160 ms





640 ms

Press the SET button to set the response time and proceed to the auto preset setting.

If the operating mode is the window comparator mode, press the SET button to return to the measuring mode.

5. Auto preset setting

This function stores the measuring pressure that is set during the auto preset mode as a basic value.

While the current setting is displayed, press the △UP or ∇DOWN button to select it as an auto preset setting.






Press the SET button to set the auto preset and return to the measuring mode.

Pressure setting

Manual setting

Press the SET button in the measuring mode to display the set value. P_{-} I and the current set value blink alternately.



Press the SET button to display the next set value. Press the \triangle UP or ∇ DOWN button to change the value. (Refer to "How to Set Value" on the lower right hand corner of this page.)

Hysteresis mode

In this mode, hysteresis (H) and the set value for hysteresis are displayed alternately after setting P1. Press the SET button to return to the normal measuring mode. Press the \triangle UP or ∇ DOWN button to change the value.

(Refer to "How to Set Value" below right.)

Window comparator mode

Normally Closed

In this mode, P2 and the current set value are displayed alternately after setting P1. Press the SET button to display the next set value (H: hysteresis). Press the \triangle UP or ∇ DOWN button to change the value.

(Refer to "How to Set Value" at right.)

Next, \forall and the set value for hysteresis will be displayed alternately. Press the SET button to return to the normal measuring mode. Press the \triangle UP or ∇ DOWN button to change the value.

(Refer to "How to Set Value" at right.)

Pressure set value can be verified without holding or stopping the switch output operation.

Auto preset setting

1. Auto preset preparation mode

While in the measuring mode, press the SET button to activate the auto preset preparation mode, and \mathbb{AP}^l will be displayed. Proceed to prepare the devices to perform the pressure setting. While \mathbb{AP}^l is still displayed, press both the \triangle UP and ∇ DOWN buttons simultaneously to return to the measuring mode.



2. Auto preset setting

Press the SET button to activate the mode to execute auto preset functions. When Π Π is displayed, start the system operation and change the pressure. The set value will be automatically detected and stored.

While \mathbb{R} is still displayed, press the SET button to complete the setting and return to the normal measuring mode.



How to Set Value

To enter a value such as the one for pressure setting:

 Press the △UP or ▽DOWN button to change the set value. The first digit blinks.



1st digi

- Press the △UP or ▽DOWN button to set the value arbitrarily. (If there is no button operation for more than 10 seconds, the current value will be automatically set and the function will return to the set value display mode.)
- With every push of the SET button, the next (higher) digit blinks.







3rd digit

When the left-most digit is zero, ", " or ", " will blink. If the SET button is pressed while the left-most digit is blinking, the right-most digit will now blink.



Press and hold the SET button for 1 second or longer to return to the set value display mode.



16-2-7

ZSE□ ISE□

PSE ⁷SE3

PS

ZSE¹₁

ZSP

ISA2

IS□

ZSM PF2□

IF□ Data

Setting

Function setting


Display calibration

During measuring mode, press the SET and ∇DOWN buttons simultaneously and hold for 2 seconds or longer. FSt and current measured value will be displayed.

Press the △UP or ▽DOWN button to change the set value. If there is no button operation for more than 2 seconds after changing the set value, the display mode returns to displaying F5L and the current measured value.



Press the SET button to display the adjusted value (percent). The adjusted value and FSI will be alternately displayed.




Press the SET button to return to the normal measuring mode.



This function eliminates slight differences in the output values and allows uniformity in the numbers displayed.

Displayed values of the pressure sensor can be calibrated to within ±5% for Series ISE and ±2.5% for Series ZSE.



Peak/Bottom hold function

This function constantly detects and updates the maximum and minimum pressure values and allows to hold the display value.


To use a peak hold function, press and hold the △UP button for 1 second or longer. The maximum pressure value is held and blinks repeatedly. Press and hold the △UP button again for 1 second or longer to release this function and return to the measuring mode.

To use a bottom hold function, press the $\nabla DOWN$ button for 1 second or longer. The minimum pressure value is held and blinks repeatedly. Press and hold ∇DOWN button again for 1 second or longer to release this function and return to the measuring mode.

Key lock function

This function prevents incorrect operations such as changing the set value accidentally. Press the SET button and hold for 4 seconds or longer to display the current Lac or Link setting. Press the \triangle UP or ∇ DOWN button to select the setting and set this function with the SET button. Use the Lacmode to avoid accidental button operation. To release a key lock function, press the SET button and hold for 4 seconds or longer to display the current setting, and select the <code>linl</code> mode.

Selection of lock and unlock




Zero out (Zero ADJ) function

This function clears and resets the displayed value as long as the measuring pressure is within ±70 digits of the atmospheric

(Due to individual product differences, the setting range varies ±10% F.S.)

This function is effective in detecting pressure fluctuations that exceed a certain amount without being affected by the supply pressure. Press and hold the $\triangle \text{UP}$ and ∇DOWN buttons simultaneously to reset the display. Release the buttons to return to the measuring mode.



Unit Conversion Function

When not selecting "M" for unit specification

Desired display unit can be selected.

Press the △UP or ▽DOWN button to switch the unit, and the set value is automatically converted.

The conversion order is: $PA \Leftrightarrow GF \Leftrightarrow bAr \Leftrightarrow PSi \Leftrightarrow inH \Leftrightarrow mmH$ Press the SET button to set the unit and proceed to the display color setting.

For vacuum/low pressure Pa⇔kgf/cm²⇔bar⇔psi⇔inchHg⇔mmHg For positive pressure MPa⇔kgf/cm²⇔bar⇔psi

Indication of Units

Displayed unit	ISE30	ZSE30	
Pa	0.001 MPa	0.2 kPa	
kgf/cm ²	0.01	0.002	
bar	0.01	0.002	
psi	0.2	0.05	
mmHg	_	2	
inchHg	_	0.2	



Description

Indication light (Green)

Displays the switch operation status.

▲UP button

Use this button to change the mode or increase the ON/OFF set value. It also allows you to switch to the peak value display mode.

SET button

Use this button to switch the mode and set the set value.

LCD display

condition, setting conditions, selected display unit, and error codes. A display color type can be selected from either a single color display with red or green, or 2-color display in which green and red are switched according to the output.

▼DOWN button

Use this button to change the mode or decrease the ON/OFF set value. It also allows you to switch to the bottom value display mode.

PSE

ZSE3

PS

ZSE;

ZSP

ISA2

IS□

ZSM

PF2□

 $\mathsf{IF}\Box$

Data

Error Correction

Take the following corrective solutions when errors occur


lake the following corrective solutions when errors occur.							
Error description	LCD display	Condition	Solution				
over- current error	Er 1	Load current of switch output is more than 80 mA.	Shut off the power supply. After eliminating the output factor that caused the excess current, turn the power supply back on.				
Residual pressure error	Er3	Pressure is applied during the zero out operation as follows: When the switch for positive pressure is used: ±0.071 MPa or more. When the switch positive pressure is used: ±7.1 kPa or more. After displaying for 3 seconds, it will return to the measuring mode. Due to the individual product difference, the setting range varies ±10% F.S.	Bring the pressure back to atmospheric pressure and try using the zero out function.				
Applied pressure error	ннн	Supply pressure exceeds the maximum regulating pressure.	Reduce/Increase supply pressure to				
	LLL	Supply pressure is below the minimum regulating pressure.	within the regulating pressure range.				
System	Er4	Internal data error	Shut off the power - supply. Turn the power supply back on. If the power should - not come back on,				
	Er5	Internal data error					
	Er7	Internal data error					
	Er8	Internal data error	please contact SMC for an inspection.				

Example of Internal Circuit and Wiring


NPN open collector output Maximum 30 V, 80 mA

Residual voltage:

1 V or less




Analog output type 1 to 5 V (±2.5% F.S.) Output impedance:




Analog output type 4 to 20 mA (±2.5% F.S.)


Maximum load impedance: Power supply voltage 12 V: 300 Ω Power supply voltage 24 V: 600 Ω Minimum load impedance: 50 Ω




PNP open collector Maximum 80 mA



Dimensions




With bracket




Dimensions

Panel mount



Panel mount adapter + Front protective cover



ZSE□

PSE

^zSE3

PS

ZSE₂

ZSP

ISA2

IS□

ZSM

PF2□


IF 🗆

Data


Dimensions

Panel fitting dimension


1-pc. mounting




Multiple (2 pcs. or more) horizontal mounting



Multiple (2 pcs. or more) vertical mounting





\triangle

Series ZSE30/ISE30

Specific Product Precautions 1

Be sure to read before handling.

Handling

△Warning

- 1. Do not drop, bump, or apply excessive impacts (980 m/s²) while handling. Although the body of the sensor may not be damaged, the internal parts of the sensor could be damaged and lead to a malfunction.
- 2. The tensile strength of the cord is 35 N. Applying a greater pulling force on it can cause a malfunction. When handling, hold the body of the sensor—do not dangle it from the cord.
- 3. Do not exceed the screw-in torque of 7 to 9 N·m when installing piping. Exceeding this value may cause malfunctioning of the sensor.
- 4. Do not use pressure sensors with corrosive and/or flammable gases or liquids.
- 5. Allow a sufficient margin of tube length in piping in order to prevent application of torsional, tensile or moment load to the tubes and fittings.
- When a brand of tubing other than SMC is used, make sure that the tolerance of the tube's O.D. satisfies the following specifications.
 - 1) Nylon tubing: ±0.1 mm or less
 - 2) Soft nylon tubing: ±0.1 mm or less
 - 3) Polyurethane tubing: +0.15 mm or less, -0.2 mm or less
- 7. The applicable fluid is air. Please consult with SMC if the switch is to be used with other types of fluids.

Connection

/∆Warning

- Incorrect wiring can damage the switch and cause a malfunction or erroneous switch output. Connections should be done while the power is turned off.
- 2. Do not attempt to insert or pull the pressure sensor or its connector when the power is on. A switch output malfunction may occur.
- 3. Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- 4. If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.

Operating Environment


∆Warning

- 1. Our pressure switches are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. Our pressure switches do not have an explosion proof rating. Never use in the presence of an explosive gas as this may cause a serious explosion.
- 3. Do not use in an environment where static electricity can cause problems, otherwise system failure or malfunction may result.

Mounting


⚠ Caution

1. Mounting with panel mount adapter



2. Mounting with bracket

Mount a bracket to the body using two M3 \times 5L mounting screws and install on piping with hexagon socket head cap screws. The switch can be installed horizontally depending on the installation location.



ZSE□ ISE□

PSE

ZSE3

PS ZSE:

| OL2

ZSP

ISA2

IS□

ZSM

PF2□

IF□

Data

\triangle


Series ZSE30/ISE30

Specific Product Precautions 2

Be sure to read before handling.

Connection/Removal of Connector


- To connect the connector, insert it straight while pinching the lever, and then push the lever into the jack of the housing and lock it.
- To remove the connector, pull it straight out while applying pressure with your thumb to the lever and unhooking it from the jack.



• Do not attempt to insert or pull the pressure sensor or its connector when the power is on. A switch output malfunction may occur.

Piping

- Cut the tube perpendicularly.
- Hold the tube and insert it into the One-touch fitting carefully and securely all the way to the bottom.




Regulating Pressure Range and Rated Pressure Range

⚠ Caution

Set the pressure within the rated pressure range.

The regulating pressure range is the range of pressure that is possible in setting.

The rated pressure range is the range of pressure that satisfies the specifications (accuracy, linearity, etc.) on the sensor. Although it is possible to set a value outside the rated pressure range, the specifications will not be guaranteed even if the value stays within the regulating pressure range.



Rated pressure range of switch

Regulating pressure range of switch